

MUNICIPAL CORPORATION CHANDIGARH
Public Health Laboratory at Water Works Sector 39.

TEST - REPORT

Not for legal use

Ref. No. & Date :- No. GMSSS-33-D/2023/908 Date:07.03.2023
Issued to :- The Principal,
Govt. Model, Sr. Sec. School,
Sector - 33 - D, Chandigarh.
Quantity of sample :- Approximate 1200 ml.
Date of Collection :- 21.03.2023
Client reference :- Sample collected by Laboratory Staff
Packing of sample :- Sample filled in P.P. and Glass Bottle.
Source of sample :- from School Tap of Govt. Model, Sr. Sec.
School, Sector - 33 - D, Chandigarh.


S. No.	Examination	Quality Standard	Unit	Results
1.	Turbidity	<1.0	N.T.U	0.7
2.	pH	7.0-8.5	---	7.78
3.	Residual Chlorine	0.2 - 0.4	mg/L	0.2
4.	Total Alkalinity (as CaCO ₃)	200	-do-	86
5.	Total Hardness (as CaCO ₃)	200	-do-	72
6.	Chlorides (as Cl)	200	-do-	04
7.	Free & Saline Ammonia	Nil	-do-	NIL
8.	Total Dissolved Solids	500	-do-	130
9.	M.P.N. of Coliform Bacilli per 100ml of water	Zero	M.P.N.	0 (Excellent)


Payment received vide Receipt No.03/2022-23/125409, date:20.03.2023 Amount Rs.3300/-.

Note:- **Water is fit for drinking.**

Lab. No. MCPHL/23/ 1326


Dated: 23 03, 2023



Chemist
MCPH Laboratory
Chandigarh


Sub Divisional Engineer,
M.C.P.H. Sub Division No. 1,
Chandigarh

Endst No. MCPHL/23/

Copy forwarded to the Medical Officer of Health Municipal Corporation, Sector-17, Chandigarh for information please.


Chemist
MCPH Laboratory
Chandigarh

Dated

Sub Divisional Engineer,
M.C.P.H. Sub Division No. 1,
Chandigarh